



Glenn Grieb
Plant Manager
Vivendi Water North America

KIN-BUC LANDFILL
383 MEADOW RD.
EDISON, NJ 08837

TELEPHONE (732) 572-4743
FACSIMILE (732) 572-6294

January 16th, 2003

Ms. Grisell V. Diaz-Cotto
Emergency and Remedial Response Division
United States Environmental Protection Agency
Region III
290 Broadway, 19th Floor
New York, NY 10007-1866

Re: December 2002 Discharge Monitoring Report
Leachate Treatment Plant, Operable Unit 1
Kin-Buc Landfill Superfund Site

Dear Ms. Diaz-Cotto:

The December 2002 Discharge Monitoring Report (DMR) for the Leachate Treatment Plant of Operable Unit 1, Kin-Buc Landfill Superfund Site, prepared by U.S. Filter Operating Services is attached. We will provide copies of the DMR to Ian Curtis and Susan Dietrick at the NJDEP.

Should you have any questions concerning the DMR or other site items, please contact me at your earliest convenience at the Kin-Buc site.

Very truly yours,
USFilter Operating Services
On behalf of SCA Services, Inc.,

Glenn Grieb
Plant Manager

Enclosure

cc: Ian Curtis – NJDEP
Susan Dietrick – NJDEP
Stephen Joyce – SCA
Carl Januszkiewicz – Waste Management
Richard Hoyt - USFilter

562179



NEW JERSEY DEPARTMENT OF ENVIRONMENTAL PROTECTION
DIVISION OF WATER QUALITY

MONITORING REPORT - TRANSMITTAL SHEET

NJPDES NO.
*
*NJ Permit Equivalent

REPORTING PERIOD
M o. Y r. M o. Y r.

PERMITTEE: Name: SCA Services, Inc.
 Address: 383 Meadow Road
 Edison, New Jersey 08817

FACILITY: Name: Kin-Buc Landfill
 Address: 383 Meadow Road
 Edison, New Jersey 08817
 Telephone: 732-572-4743

FORMS ATTACHED (Indicate Quantity of Each)

Operating Exceptions

SLUDGE REPORT-SANITARY
__ T-VWX-007 __ T-VWX-008 __ T-VWX-009
__ EPA Form 3320-1

DYE TESTING YES NO
 __ X

SLUDGE REPORT-INDUSTRIAL
__ T-VWX-010A __ T-VWX-010B

TEMPORARY BYPASSING __ X

DISINFECTION INTERRUPTION __ X

WASTEWATER REPORTS
__ T-VWX-011 __ T-VWX-012 __ T-VWX-013

MONITORING MALFUNCTIONS __ X

GROUNDWATER REPORTS
__ T-VWX-015(A,B) __ T-VWX-016 __ T-VWX-017
__ ELECTRONIC SUBMISSION

UNITS OF OPERATION __ X

OTHER __ X

NPDES DISCHARGE MONITORING
__ EPA Form 3320-1


(Detail any "Yes" on reverse side in appropriate space.)


NOTE: The "Hours Attended at Plant" on the reverse of this sheet must also be completed.

AUTHENTICATION I certify under penalty of law that this document and all attachments were prepared under the direction or supervision in accordance with a system designed to assure my inquiry of the person or persons who manage the system or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

LICENSED OPERATOR

PRINCIPAL EXECUTIVE OFFICER OR
DULY AUTHORIZED REPRESENTATIVE

Name (Printed) Glenn Grieb
Grade & Registry No. N-4 0021212
Signature 

Name (Printed) Glenn Grieb
Title (Printed) Plant Operations Manager
Signature 

PERMITTEE NAME/ADDRESS

NAME
ADDRESS

FACILITY
LOCATION

SCA SERVICES, INC.
383 MEADOW ROAD
EDISON, NEW JERSEY 08817

KIN-BUC LANDFILL
EDISON, NEW JERSEY
CARL JANUSZKIEWICZ

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT
PERMIT NUMBER

001
DISCHARGE NUMBER

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
02	12	01	02	12	31

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
FLOW	SAMPLE MEASUREMENT	0.030840	0.038367	MGD	*****	*****	*****	***	***	continuous	flow meter
	PERMIT REQUIREMENT	REPORT	ONLY		*****	*****	*****			continuous	flow meter
pH	SAMPLE MEASUREMENT	*****	*****	***	7.23	*****	8.17	S.U.	0	1/week	grab
	PERMIT REQUIREMENT	*****	*****		6.0	*****	9.0			weekly	grab
PETROLEUM HYDROCARBONS	SAMPLE MEASUREMENT	*****	*****	***	*****	<1.00	<1.00	mg/l	0	2/month	grab
	PERMIT REQUIREMENT	*****	*****		*****	10	15			2/month	grab
COD	SAMPLE MEASUREMENT	18.81	19.15	kg/day	*****	161	167	mg/l	0	2/month	comp.
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT	ONLY			2/month	comp.
BOD	SAMPLE MEASUREMENT	*****	*****	***	*****	5.80	6.60	mg/l	0	2/month	comp.
	PERMIT REQUIREMENT	*****	*****		*****	56	220			2/month	comp.
TOTAL SUSPENDED SOLIDS	SAMPLE MEASUREMENT	<1.1993	<1.2320	kg/day	*****	<10.00	<10.00	mg/l	0	1/week	comp.
	PERMIT REQUIREMENT	REPORT	ONLY		*****	30	45(1)			weekly	comp.
DISSOLVED OXYGEN	SAMPLE MEASUREMENT	*****	*****	***	8.81	*****	*****	mg/l	0	1/week	grab
	PERMIT REQUIREMENT	*****	*****		4.0 MIN. Instantaneous	*****	*****			weekly	grab
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that I have personally examined and I am familiar with the information submitted herein, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 & 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years)					TELEPHONE		DATE		
Glenn Grieb Project Manager							732 572-4743		2003 1 16		
TYPED OR PRINTED							AREA CODE NUMBER		YEAR MO DAY		
		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT									

COMMENTS AND EXPLANATIONS OF ANY VIOLATIONS

(REFERENCE ALL ATTACHMENTS HERE)

PERMITTEE NAME/ADDRESS
NAME
ADDRESS

FACILITY
LOCATION
ATTN:

SCA SERVICES, INC.
383 MEADOW ROAD
EDISON, NEW JERSEY 08817

KIN-BUC LANDFILL
EDISON, NEW JERSEY
CARL JANUSZKIEWICZ

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT			001		
PERMIT NUMBER			DISCHARGE NUMBER		
MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
02	12	01	02	12	31

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
BENZENE	SAMPLE MEASUREMENT	<0.00003	<0.00003	kg/day	*****	<0.22	<0.22	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.009	0.02		*****	57	134			2/month	grab
CHLOROBENZENE	SAMPLE MEASUREMENT	<0.00003	<0.00003	kg/day	*****	<0.25	<0.25	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.022	0.058		*****	142	380			2/month	grab
1,1 DICHLOROETHENE	SAMPLE MEASUREMENT	<0.00003	<0.00003	kg/day	*****	<0.24	<0.24	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.003	0.009		*****	22	59			2/month	grab
ETHYLBENZENE	SAMPLE MEASUREMENT	<0.00002	<0.00002	kg/day	*****	<0.18	<0.18	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.022	0.058		*****	142	380			2/month	grab
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT	<0.00003	<0.00003	kg/day	*****	<0.23	<0.23	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.008	0.025		*****	52	154			2/month	grab
TOLUENE	SAMPLE MEASUREMENT	<0.00003	<0.00003	kg/day	*****	<0.24	<0.24	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.004	0.011		*****	28	74			2/month	grab
1,2-TRANSDICHLOROETHYLENE	SAMPLE MEASUREMENT	<0.00004	<0.00004	kg/day	*****	<0.34	<0.34	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.004	0.009		*****	25	80			2/month	grab
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that I have personally examined and I am familiar with the information submitted herein, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 & 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years.)				TELEPHONE		DATE			
Glenn Grieb Project Manager						732 572-4743		2003 1 16			
TYPED OR PRINTED		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT				AREA CODE NUMBER		YEAR MO DAY			

COMMENTS AND EXPLANATIONS OF ANY VIOLATIONS (REFERENCE ALL ATTACHMENTS HERE)

PERMITTEE NAME/ADDRESS

NAME

ADDRESS

SCA SERVICES, INC.
383 MEADOW ROAD
EDISON, NEW JERSEY 08817

FACILITY

LOCATION


ATTN:

KIN-BUC LANDFILL
EDISON, NEW JERSEY
CARL JANUSZKIEWICZ

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT	001
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
02	12	01		02	12	31

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
TRICHLOROETHYLENE	SAMPLE MEASUREMENT	<0.00003	<0.00003	kg/day	*****	<0.26	<0.26	ug/L	0	2/month	grab
	PERMIT REQUIREMENT	0.004	0.010		*****	26	69			2/month	grab
VINYL CHLORIDE	SAMPLE MEASUREMENT	<0.00003	<0.00003	kg/day	*****	<0.28	<0.28	ug/L	0	1/week	grab
	PERMIT REQUIREMENT	0.008	0.016		*****	52.8	106			weekly	grab
ACENAPHTHYLENE	SAMPLE MEASUREMENT	<0.00002	<0.00002	kg/day	*****	<0.20	<0.20	ug/L	0	1/month	grab
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab
BENZO(A)ANTHRACENE	SAMPLE MEASUREMENT	<0.000023	<0.000024	kg/day	*****	<0.20	<0.20	ug/L	0	1/month	grab
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab
BENZO(A)PYRENE	SAMPLE MEASUREMENT	<0.000047	<0.000048	kg/day	*****	<0.40	<0.40	ug/L	0	1/month	grab
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab
BENZO(ghi)PERYLENE	SAMPLE MEASUREMENT	<0.000117	<0.000119	kg/day	*****	<1.00	<1.00	ug/L	0	1/month	grab
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab
BENZO(k)FLUORANTHENE	SAMPLE MEASUREMENT	<0.000011	<0.000011	kg/day	*****	<0.092	<0.092	ug/L	0	1/month	grab
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that I have personally examined and I am familiar with the information submitted herein, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 & 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years)						TELEPHONE		DATE	
Glenn Grieb Project Manager		 SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT						732 572-4743		2003 1 16	
TYPED OR PRINTED								AREA CODE		NUMBER	

COMMENTS AND EXPLANATIONS OF ANY VIOLATIONS

(REFERENCE ALL ATTACHMENTS HERE)

<0.00017

PERMITTEE NAME/ADDRESS

NAME **SCA SERVICES, INC.**
 ADDRESS **383 MEADOW ROAD**
EDISON, NEW JERSEY 08817

FACILITY **KIN-BUC LANDFILL**
 LOCATION **EDISON, NEW JERSEY**
 ATTN: **CARL JANUSZKIEWICZ**

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
 DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT	001
PERMIT NUMBER	DISCHARGE NUMBER

MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
02	12	01		02	12	31

PARAMETER		QUANTITY OR LOAD			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE		
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			YEAR	MO	DAY
IDENO(1,2,3cd) PYRENE	SAMPLE MEASUREMENT	<0.000094	<0.000095	kg/day	*****	<0.80	<0.80	ug/L	0	1/month	grab		
	PERMIT REQUIREMENT	0.00026	0.00052		*****	1.72	3.43			monthly	grab		
PHENANTHRENE	SAMPLE MEASUREMENT	<0.000024	<0.000025	kg/day	*****	<0.20	<0.20	ug/L	0	1/week	grab		
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	5.4(2)			weekly	grab		
ALDRIN	SAMPLE MEASUREMENT	<0.000001	<0.000001	kg/day	*****	<0.01	<0.01	ug/L	0	1/month	grab		
	PERMIT REQUIREMENT	0.000133	0.00026		*****	0.0875	0.175			monthly	grab		
4,4-DDT	SAMPLE MEASUREMENT	<0.000001	<0.000003	kg/day	*****	<0.01	<0.02	ug/L	0	1/week	grab		
	PERMIT REQUIREMENT	0.0000576	0.000145		*****	0.38	0.765			weekly	grab		
PCB-1242	SAMPLE MEASUREMENT	<0.000024	<0.000025	kg/day	*****	<0.20	<0.20	ug/L	0	1/week	grab		
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	0.5(2)			weekly	grab		
PCB-1248	SAMPLE MEASUREMENT	<0.000024	<0.000025	kg/day	*****	<0.20	<0.20	ug/L	0	1/week	grab		
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	0.5(2)			weekly	grab		
PCB-1254	SAMPLE MEASUREMENT	<0.000024	<0.000025	kg/day	*****	<0.20	<0.20	ug/L	0	1/week	grab		
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	0.5(2)			weekly	grab		
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that I have personally examined and I am familiar with the information submitted herein, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 & 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years)						TELEPHONE		DATE			
Glenn Grieb Project Manager								732 572-4743		2003 1 16			
TYPED OR PRINTED								SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE NUMBER		YEAR MO DAY	

PERMITTEE NAME/ADDRESS

NAME

ADDRESS

FACILITY

LOCATION

ATTN:

SCA SERVICES, INC.
383 MEADOW ROAD
EDISON, NEW JERSEY 08817

KIN-BUC LANDFILL
EDISON, NEW JERSEY
CARL JANUSZKIEWICZ

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
 DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT
 PERMIT NUMBER

001
 DISCHARGE NUMBER

MONITORING PERIOD
 YEAR MO DAY TO YEAR MO DAY
02 12 01 TO **02 12 31**

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE		
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			YEAR	MO	DAY
PCB-1260	SAMPLE MEASUREMENT	<0.000024	<0.000025	kg/day	*****	<0.20	<0.20	ug/L	0	1/week	grab		
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	0.5(2)			weekly	grab		
ARSENIC	SAMPLE MEASUREMENT	<0.000410	<0.000422	kg/day	*****	<3.42	<3.50	ug/L	0	1/week	comp		
	PERMIT REQUIREMENT	0.013	0.026		*****	85.8	172			weekly	comp		
CADMIUM	SAMPLE MEASUREMENT	<0.000048	<0.000049	kg/day	*****	<0.40	<0.40	ug/L	0	1/week	comp		
	PERMIT REQUIREMENT	0.0073	0.017		*****	48.2	112			weekly	comp		
CHROMIUM	SAMPLE MEASUREMENT	0.000376	0.000410	kg/day	*****	3.14	3.40	ug/L	0	1/week	comp		
	PERMIT REQUIREMENT	0.830	0.860		*****	198	396			weekly	comp		
COPPER	SAMPLE MEASUREMENT	0.000325	0.000470	kg/day	*****	2.7	3.9	ug/L	0	1/week	comp		
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	10			weekly	comp		
LEAD	SAMPLE MEASUREMENT	0.000232	0.000444	kg/day	*****	1.9	3.6	ug/L	0	1/week	comp		
	PERMIT REQUIREMENT	REPORT	ONLY		*****	REPORT ONLY	10			weekly	comp		
NICKEL	SAMPLE MEASUREMENT	0.002390	0.002748	kg/day	*****	19.9	22.5	ug/L	0	1/week	comp		
	PERMIT REQUIREMENT	0.140	0.281		*****	924	1850			weekly	comp		
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that I have personally examined and I am familiar with the information submitted herein, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 & 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months and 5 years)					TELEPHONE		DATE				
Glenn Grieb Project Manager							732 572-4743		2003 1 16				
TYPED OR PRINTED							SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		AREA CODE	NUMBER		YEAR	MO

COMMENTS AND EXPLANATIONS OF ANY VIOLATIONS

(REFERENCE ALL ATTACHMENTS HERE)

PERMITTEE NAME/ADDRESS

NAME
ADDRESS

FACILITY
LOCATION
ATTN:

SCA SERVICES, INC.
383 MEADOW ROAD
EDISON, NEW JERSEY 08817

KIN-BUC LANDFILL
EDISON, NEW JERSEY
CARL JANUSZKIEWICZ

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM
DISCHARGE MONITORING REPORT

NJ PERMIT EQUIVALENT			001			
PERMIT NUMBER			DISCHARGE NUMBER			
MONITORING PERIOD						
YEAR	MO	DAY	TO	YEAR	MO	DAY
02	12	01		02	12	31

PARAMETER		QUANTITY OR LOADING			QUALITY OR CONCENTRATION				NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
		AVERAGE	MAXIMUM	UNITS	MINIMUM	AVERAGE	MAXIMUM	UNITS			
ZINC	SAMPLE MEASUREMENT	0.002116	0.002908	kg/day	*****	17.6	24.4	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	0.177	0.358		*****	1178	2350			weekly	comp
CYANIDE	SAMPLE MEASUREMENT	<0.001199	<0.001232	kg/day	*****	<10.00	<10.00	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	0.002	0.004		*****	18.2	26.4			weekly	comp
ALUMINUM	SAMPLE MEASUREMENT	<0.009282	<0.009536	kg/day	*****	<77.40	<77.40	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	1.40	2.81		*****	9240	18508			weekly	comp
IRON	SAMPLE MEASUREMENT	0.005868	0.006985	kg/day	*****	48.78	56.70	ug/L	0	1/week	comp
	PERMIT REQUIREMENT	80.6	162		*****	532000	5070000			weekly	comp
ACUTE TOXICITY, (LC50)	SAMPLE MEASUREMENT	QUARTELY	REPORT	***	N/A	*****	*****	%	0	Quarterly	Report
	PERMIT REQUIREMENT	*****	*****		50(3)	*****	*****			see permit	equivalent
Ammonia	SAMPLE MEASUREMENT	*****	*****	***	*****	0.1050	0.1100	mg/l	0	*****	*****
	PERMIT REQUIREMENT	*****	*****		*****	4.5	10.0			2/month	comp
	SAMPLE MEASUREMENT	*****	*****	***	*****	*****	*****	***	***	*****	*****
	PERMIT REQUIREMENT	*****	*****		*****	*****	*****			*****	*****
NAME/TITLE PRINCIPAL EXECUTIVE OFFICER		I certify under penalty of law that I have personally examined and am familiar with the information submitted herein, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment. See 18 U.S.C. 1001 & 33 U.S.C. 1319. (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months and 5 years)				TELEPHONE		DATE			
Glenn Grieb Project Manager						732 572-4743		2003 1 16			
TYPED OR PRINTED						AREA CODE NUMBER		YEAR MC DAY			

COMMENTS AND EXPLANATIONS OF ANY VIOLATIONS

(REFERENCE ALL ATTACHMENTS HERE)